

QUALITY CERTIFICATE

Vessel	"Submitted "	Port	Providence, RI	Report	121504
Customer	Sprague Energy	Date	December 5, 2004	Reference	
Operation	Analysis	Terminal	Sprague Providence	Sample #	685504

Name of material being tested Description of sample source Samples Drawn by (company) Samples Tested by (company)

No 6 Fuel Oil

Shore Tank # 6 After Discharge BSi Inspectorate BSi Inspectorate

Test method	Sample Results	
D - 4052 D - 93 D - 445 D - 2161 D - 97 D - 4294 D - 1796 D - 473	11.8 / 0.9871 184 184.1 87.3 9 / 48 0.982 0.400 0.04	
D - 240 D - 240 D - 482 D - 5863 B D - 5863 B	0.4 18,286.80 151,334.24 0.069 28 17 0.34	
IP - 143 D - 189	3.64 9.850	
SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS REPRESENTING THE SPECIFICATIONS OF THE PRODUCT AT THE SPRAGUE TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE. THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF ESTABLISHING THE INDEPENDENTLY VERIFIED PRODUCT SPECIFICATION ON A COMPOSITE BASIS IN SPRAGUE'S TERMINAL SHORE TANK AS NOTED. IN THE CERTIFICATE. THE INSPECTION REPORT IS NOT TO BE USED FOR ANY INTERPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR THE PRODUCT AFTER DELIVERY BY SPRAGUE TO CUSTOMER. SPRAGUE DISCLAIMS ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR AN INTENDED USE EXCEPT AS MAY BE SPECIFICALLY SET FORTH IN WRITING IN ANY CONTRACT OR TERMS OF SALE BETWEEN SPRAGUE AND A BUYER OF PRODUCT, SPRAGUE ASSUMES NO LIABILITY FOR CLAIMS OR LOSSES THAT MAY ARISE FROM CUSTOMER'S USE OF THIS INSPECTION REPORT/ANALYSIS.		
	D - 4052 D - 93 D - 445 D - 2161 D - 97 D - 4294 D - 1796 D - 473 D - 95 D - 240 D - 240 D - 240 D - 5863 B D - 5863 B D - 5762 IP - 143 D - 189 YSIS SPRAGUE E CERTIFICATE. DSE OF FICATION ON JOTEON THE R ANY JER JITY OF AY BE SPECIFICALLY JETWEEN SPRAGUE CLAIMS OR LOSSES	

^{**} Annotates Analysis Contracted Out

Michael White

^{***} Annotates Loadport information- this test was not performed by Inspectorate